

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Dated: 23/06/2025

No. 30


It is certified that an inspection team headed by ..Mr.. DEVKI.NANDAN.JOSHI..QUALITY MANAGER  
(Name of Officers with designation) from ..UTTARAKHAND JAL SANSTHAN  
inspected the ..ATAL..UT.KRISHNA..SSSS..G.S.NEGI..G.I.C.BHAT.KHOLA, BAGESHWAR  
(Name & Address of the school) on ..23/06/2025.(date of inspection) and on the basis of  
Water Test Report (Attached) bearing no. 30/UIS/DLWQTM/2025-26 dated....21-06-2025  
of DISTRICT LEVEL WATER QUALITY  
TESTING AND MONITORING LAB (PHED Lab) certified that the  
A.U.SSSS..G.S.NEGI..G.I.C.BHAT.KHOLA( Name of school) has safe drinking water  
facilities for the students and members of staff of the institution. School is also maintains the  
hygienic sanitation condition in the school building & the campus as per norms prescribed by the  
Central/ State/ U.T. Govt.

This certificate is valid till ..ONE (01) YEAR

Quality Manager

Distt. Water Quality Testing

Monitoring Laboratory

Signature with Seal:  UTTARAKHAND JAL SANSTHAN, BAGESHWAR

Name : DEVKI.NANDAN.JOSHI.

Designation : ..QUALITY. MANAGER.

Name & Address of the Office / Department : UTTARAKHAND

JAL SANSTHAN, BAGESHWAR

To

...A.U.SSSS..G.S.NEGI.....

...G.I.C.BHAT.KHOLA, BAGESHWAR

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**District Level Water Quality Testing and Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, Bageshwar**



TC-13234

**TEST REPORT**

Name and Address of Organization/ Customer	Atal Utkrisht S.S.S.S.G.S. Negi GIC Bhatkhola, Bageshwar			
Test Report ID	30/UJS/DLWQTM/2025-26	Reporting Date	21-06-2025	
ULR No.	TC1323425000000030F	Sample Location	GIC Bhatkhola	
Product Description	Drinking Water	Sample Collected by	Customer	
Reference Sample Identification:	DLWQTM/UJS/AB-01			
Date of Start of Analysis:	20-06-2025			
Date of End of Analysis:	21-06-2025			
Date and Time of Sample Received:	20-06-2025 02:30PM			

N	Parameters	Test Method	Result	Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1	pH at 25°C	IS 3025 (Part 11) 2022,	7.67	6.5 to 8.5	No Relaxation
2	Total Dissolved Solids (TDS), at 180°C mg/L, Max	IS 3025 (Part 16), 2023	292	500	2000
3	Turbidity, NTU, Max	IS 3025 (Part 10), 2023	0.79	1	5
4	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L, Max	IS 3025 (Part 23), 2023	190	200	600
5	Total Hardness (as CaCO <sub>3</sub> ), mg/L, Max	IS 3025 (Part 21), 2009	212	200	600
6	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019	40	75	200
7	Chloride, mg/L, Max	IS 3025 (Part 32), 2019	17.82	250	1000
8	Magnesium as Mg, mg/l	APHA 24 <sup>th</sup> Ed -3500-Mg Method B:2023 (Calculation Method)	27.21	30	100
9	Colour, Hazen, Max	IS 3025 (Part 4): 2021	Less Than 5	5	15
10	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable

Note:

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer.
4. The results apply to the sample as received.
5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

\*\*\*\* End of Report\*\*\*\*

Review and Authorized By

Authorized Signatory  
(K. K. Panigrahi)  
Technical Manager, Lab



**District Level Water Quality Testing and Monitoring Laboratory**  
**Uttarakhand Jal Sansthan, Bageshwar**  
 Ph (OFFICE): 05963-220038, E-mail: eeujsbgr@gmail.com

**TEST REPORT**

Name and Address of Organization/ Customer	Atal Utkrisht S.S.S.S.G.S. Negi G.I.C. Bhatkhola, Bageshwar		
Test Report ID	30-B/UJS/DLWQTM/2025-26	Reporting Date	21-06-2025
ULR No.	TC1323425000000030F	Sample Location	GIC Bhatkhola
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTM/UJS/AB-01		
Date of Start of Analysis:	20-06-2025		
Date of End of Analysis:	21-06-2025		
Date and Time of Sample Received:	20-06-2025 02:30PM		

**Bacteriological Parameters**

SN	Water Quality Parameters Under Biological Scope	Results	Desirable Limit (BIS)	Permissible Limit(BIS) In the Absence of alternative source	Std. Test Method
1	Total Coliform, MPN/100ML	Absent	Absent	Absent	APHA 23rd Ed.-9223 B
2	E-Coli, MPN/100ML	Absent	Absent	Absent	APHA 23rd Ed.-9223.B



-End of Report-

1. The results listed refer only to tested sample and applicable parameters.
2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory.
3. The samples will be destroyed after fifteen days from the date of issue of test certificate, unless otherwise agreed with customer.